Seasonic Vertex GX-850

Lab ID SS85002116

Certification ID 252116

Test Result Report ID: 23PS2116A

Certificate Issue Date: Jan 20, 2023

Scheme: ETA-EMI PSU

115V



230V



Scheme: LAMBDA PSU

115V



230V





Outside Validation Scope



General Information

Test Equipment

Electronic Loads	Chroma 63601-5 x2 Chroma 63600-2 Chroma 63640-80-80 x10 Chroma 63610-80-20
AC Sources	Chroma 6530, APM SP300VAC4000W-P, GW Instek ASR-3500
Power Analyzers	Rohde & Schwarz HMC8015 & NPA701
Oscilloscopes	Picoscope 4444, Siglent SDS2104X PLUS
Sound Analyzer	Bruel & Kjaer 2270 G4
Microphone	Bruel & Kjaer Type 4955-A
Temperature Logger	Picoscope TC-08
Tachometer	UNI-T UT372
Multimeters	Keysight 34465A
EMI Analyzer	TekBox TBMR-110M-EU
Isolation Transformer	4kVA
UPS	FSP Champ Tower 3kVA, CyberPower OLS3000E 3kVA
Testing Methodology	Cybenetics PSU Test Protocol

DUT Information
(Non-accredited measurements)

Product Identification Details	
Brand	Seasonic
Model	Vertex GX-850
OEM/ODM	Seasonic
Serial Number	
Product Specifications	
Manufacturer-Provided Information	
□□□□ (Vrms)	100-240

□□□□ (Arms)	11-5.5
□□□□ (Hz)	50-60
□□□□ (W)	850
Operating Temperature (Continuous Full Load) (°C)	
□□	ATX12V
□□□□	Fully Modular
Warranty	-
Cybenetics Measurements	
Dimensions (W x H x D)	
Weight	
□□	135mm Fluid Dynamic Bearing Fan (HA13525H12F-Z)
□□□□□	✓ (selectable)
Cybenetics Testing Information	
Lab ID	SS85002116
Date of receipt	Dec 12, 2022
Testing Date	Jan 20, 2023
Report Issued Date	Jan 20, 2023
Engineer Name	-
Authorized By the Laboratory Technical Manager	Aristeidis Bitziopoulos
Signature	

□□□□□
(Non-accredited measurements)

□□□□□				
□□	□□□□	□□□□□□	Gauge	In Cable Capacitors
ATX □□ 20+4 pin (620mm)	1	1	16-18AWG	□
4+4 pin EPS 12V □□ (710mm)	2	2	16AWG	□
6+2pin PCIe□□ (760mm)	3	3	16AWG	□
12+4 pin PCIe (760mm) (600W)	1	1	16-28AWG	□

SATA□□ 3.3 (410mm+150mm)	1	2	18AWG	□
SATA□□ (510mm+150mm+150mm+150mm)	4	16	18AWG	□
4-pin Molex (460mm+130mm+130mm)	1	3	18AWG	□
AC Power Cord (1400mm) - C13 coupler	1	1	18AWG	-

□□□□

□		3.3V	5V	12V	5VSB	-12V
□□□□	□□	20	20	70	3	0.3
	□	100		840	15	3.6
□□□□□ (W)		850				

Test Results

Temperature & Compliance Info

□□□□ (°C /°F)	28-32 / 82.4-89.6
□□ ErP Lot3/6□□	✓
□□ (EU) No 617/2013□□	✓
ALPM (Alternative Low Power Mode) compatible	✓
ATX v3.0 Compliance	✓

Performance Summary

115V

Accredited	
□□□□ (>1450 load combinations)	89.407%
Average Noise Output (>1450 Load Combinations)	24.54dBA
PF□□□ (>1450 Load Combinations)	0.984
Efficiency With 10W (≤500W) or 2% (>500W) Load	73.042%
□□□□□□	0.0659W
Non-Accredited	

12V Ripple (Full Load)	23.35mV
5V Ripple (Full Load)	12.10mV
3.3V Ripple (Full Load)	16.01mV
5VSB Ripple (Full Load)	27.81mV
12V Load Regulation	1.13%
5V Load Regulation	0.68%
3.3V Load Regulation	0.45%
5VSB Load Regulation	2.31%
Inrush Current	35.740A

230V

Accredited	
□□□□ (>1450 load combinations)	91.460%
Average Noise Output (>1450 Load Combinations)	24.51dBA
PF□□□ (>1450 Load Combinations)	0.947
Efficiency With 10W (≤500W) or 2% (>500W) Load	71.931%
□□□□□□	0.1398W
Non-Accredited	
12V Ripple (Full Load)	23.82mV
5V Ripple (Full Load)	11.85mV
3.3V Ripple (Full Load)	15.39mV
5VSB Ripple (Full Load)	27.09mV
12V Load Regulation	1.15%
5V Load Regulation	0.68%
3.3V Load Regulation	0.42%
5VSB Load Regulation	2.33%
Inrush Current	67.300A
12V Transient Response (200%)	11.60V
5V Transient Response (200%)	4.956V
3.3V Transient Response (200%)	3.260V
5VSB Transient Response (200%)	4.977V
□□□□ & PG□□	25.90ms

AC Loss to PWR_OK Hold Up Time		21.30ms
PWR_OK Inactive to DC Loss Delay		4.60ms
PSU Timings: T1 (20% / 100%)	73.0ms	72.0ms
PSU Timings: T3 (20% / 100%)	128.0ms	126.0ms
OPP (26.14°C / 40.43°C)	139.80%	139.79%

□□□□ & PG□□

Hold-Up Time (ms)	25.9
AC Loss to PWR_OK Hold Up Time (ms)	21.3
PWR_OK Inactive to DC Loss Delay (ms)	4.6

□□□□

Tables

115V

Detailed Results						
	Average	Min	Limit Min	Max	Limit Max	Result
Mains Voltage RMS:	115.15 V	115.14 V	113.85 V	115.17 V	116.15 V	PASS
Mains Frequency:	60.00 Hz	59.94 Hz	59.40 Hz	60.01 Hz	60.60 Hz	PASS
Mains Voltage CF:	1.415	1.415	1.340	1.416	1.490	PASS
Mains Voltage THD:	0.13 %	0.11 %	N/A	0.15 %	2.00 %	PASS
Real Power:	0.066 W	0.061 W	N/A	0.071 W	N/A	N/A
Apparent Power:	9.983 W	9.979 W	N/A	9.986 W	N/A	N/A
Power Factor:	0.007	N/A	N/A	N/A	N/A	N/A


230V

Detailed Results						
	Average	Min	Limit Min	Max	Limit Max	Result

Mains Voltage RMS:	230.37 V	230.35 V	227.70 V	230.39 V	232.30 V	PASS
Mains Frequency:	50.00 Hz	50.00 Hz	49.50 Hz	50.00 Hz	50.50 Hz	PASS
Mains Voltage CF:	1.415	1.415	1.340	1.416	1.490	PASS
Mains Voltage THD:	0.15 %	0.13 %	N/A	0.16 %	2.00 %	PASS
Real Power:	0.140 W	0.125 W	N/A	0.153 W	N/A	N/A
Apparent Power:	33.395 W	33.387 W	N/A	33.404 W	N/A	N/A
Power Factor:	0.004	N/A	N/A	N/A	N/A	N/A

□□□□□□


115V




□□

This graph depicts the PSU`s efficiency throughout its entire operational range. For the generation of the efficiency and noise graphs we set our loaders to auto mode through our custom-made software before trying thousands of possible load combinations


230V



This graph depicts the PSU`s efficiency throughout its entire operational range. For the generation of the efficiency and noise graphs we set our loaders to auto mode through our custom-made software before trying thousands of possible load combinations



axis starts at 83



axis starts at 0.80

Load range	Points	Efficiency 115V	Efficiency 230V	PF 115V	PF 230V
0-<20 %	228 / 228	84.96%	85.86%	0.962	0.832
20-<40 %	331 / 331	90.58%	92.05%	0.985	0.944
40-<60 %	327 / 327	90.91%	92.91%	0.987	0.967
60-<80 %	333 / 333	90.17%	92.69%	0.988	0.976
80-100 %	334 / 333	89.04%	92.06%	0.990	0.981
70-100 % (High-Load)	505 / 504	89.34%	92.23%	0.990	0.980
All (published average)	1553 / 1552	89.41%	91.46%	0.984	0.947


INFO

The average efficiency and power factor in five ranges of load. Calculated from the 1553 (115V) and 1552 (230V) load combinations of the certification sweep, the same data that ETA and LAMBDA use (test 0 excluded). Load is the total DC output as a share of the rated 850 W. These are plain averages of the valid readings, as for the ETA rating, so the ranges combined give back the published averages.

Informational. Not part of the ETA or LAMBDA rating.

□□□□□


115V



□□

The PSU`s noise in its entire operational range and under 30-32 °C ambient is depicted in this graph. The X axis represents the load on the +12V rail(s) while the Y axis is the load on the minor rails


230V



The PSU`s noise in its entire operational range and under 30-32 °C ambient is depicted in this graph. The X axis represents the load on the +12V rail(s) while the Y axis is the load on the minor rails

Noise by load range

High-Load Index (70-100 % load)
Noise **28.7 dB(A)** at 115V and **28.7 dB(A)** at 230V · loudest point 32.1 dB(A)
Efficiency 89.34% / 92.23% · power factor 0.990 / 0.980 (115V / 230V)



Load range	Noise 115V avg (loudest)	Noise 230V avg (loudest)	Fan off 115V / 230V
0-<20 %	<6.0 (<6.0)	<6.0 (<6.0)	100% / 100%
20-<40 %	12.8 (20.2)	12.7 (20.2)	80% / 80%
40-<60 %	20.2 (21.9)	20.2 (21.9)	1% / 1%
60-<80 %	24.2 (27.9)	24.2 (27.9)	0% / 0%
80-100 %	29.8 (32.1)	29.7 (32.1)	0% / 0%
70-100 % (High-Load)	28.7 (32.1)	28.7 (32.1)	0% / 0%
All (published average)	24.6 (32.1)	24.5 (32.1)	32% / 32%

INFO

The average noise in five ranges of load, the share of points with the fan stopped (semi-passive operation), and the High-Load Index: the same figures for all points at 70 % of the rated output and above. Calculated from the 1553 (115V) and 1552 (230V) load combinations of the certification sweep, the same data that ETA and LAMBDA use (test 0 excluded). Load is the total DC output as a share of the rated 850 W. Noise is averaged on the energy scale, as for LAMBDA, so the ranges combined give back the published average noise. Each load combination is held for about five seconds; the stabilized readings at fixed loads are under "Noise under high ambient temperature". Below 6 dB(A), the floor of our sound meter, the table and the chart show <6.0. In the averages a stopped fan counts as 5 dB(A),

as in the published average.

Informational. Not part of the ETA or LAMBDA rating.

Noise under high ambient temperature (indicative)

115V

Load	Normal ambient fan · noise · intake	High ambient fan · noise · intake	Noise change
10%	0 RPM · <6.0 dB(A) · 44.6 °C	0 RPM · <6.0 dB(A) · 44.6 °C	fan off in both
20%	0 RPM · <6.0 dB(A) · 45.5 °C	0 RPM · <6.0 dB(A) · 45.5 °C	fan off in both
50%	757 RPM · 20.4 dB(A) · 42.2 °C	757 RPM · 20.4 dB(A) · 42.2 °C	**+0.0 dB(A)**
100%	1196 RPM · 34.4 dB(A) · 45.1 °C	1196 RPM · 34.4 dB(A) · 45.1 °C	**+0.0 dB(A)**

230V


Load	Normal ambient fan · noise · intake	High ambient fan · noise · intake	Noise change
10%	0 RPM · <6.0 dB(A) · 44.4 °C	0 RPM · <6.0 dB(A) · 44.4 °C	fan off in both
20%	0 RPM · <6.0 dB(A) · 45.2 °C	0 RPM · <6.0 dB(A) · 45.2 °C	fan off in both
50%	757 RPM · 20.4 dB(A) · 42.1 °C	757 RPM · 20.4 dB(A) · 42.1 °C	**+0.0 dB(A)**
100%	1174 RPM · 33.8 dB(A) · 45.2 °C	1174 RPM · 33.8 dB(A) · 45.2 °C	**+0.0 dB(A)**

INFO

Fan speed, noise and the measured intake temperature at 10, 20, 50 and 100 % load, from the two load regulation tests: at normal ambient (about 30-32 °C) and at high ambient (about 40-47 °C). These are stabilized readings at fixed loads, not averages over the certification sweep, so they are indicative of how the fan behaves when it is hot. "<6.0" is the floor of our sound meter: the fan is stopped or too quiet to measure (the fan speed column says which); with the fan stopped, the intake sensor can read higher than the chamber air.


Informational. Not part of the ETA or LAMBDA rating.

Indicative Performance



The PSU`s efficiency under high ambient temperatures with 115V and 230V input. For this graph the results of the 10-110% load regulation table are used

5Vsb□□□□



□□

This graph depicts the efficiency levels of the 5VSB rail with 115V and 230V input

□□□□ □□ 5Vsb □□ (ErP Lot3/6 & CEC)

115V

□□ #	5VSB	DC/AC (□)	□□	PF/AC □□
1	0.045A	0.231W	65.88%	0.035
	5.141V	0.351W		115.15V
2	0.09A	0.463W	72.616%	0.063
	5.14V	0.638W		115.15V
3	0.55A	2.823W	81.327%	0.269
	5.13V	3.471W		115.16V
4	1A	5.123W	81.874%	0.372
	5.121V	6.257W		115.15V
5	1.5A	7.668W	81.284%	0.428
	5.11V	9.433W		115.15V
6	3A	15.234W	79.215%	0.502
	5.077V	19.231W		115.15V

230V

□□ #	5VSB	DC/AC (□)	□□	PF/AC □□
1	0.045A	0.231W	52.673%	0.013
	5.14V	0.439W		230.38V
2	0.09A	0.463W	63.155%	0.022
	5.14V	0.733W		230.38V
3	0.55A	2.822W	78.671%	0.103
	5.13V	3.588W		230.38V
4	1A	5.122W	80.481%	0.17
	5.121V	6.363W		230.37V
5	1.5A	7.668W	80.357%	0.231
	5.111V	9.543W		230.37V
6	3A	15.239W	81.034%	0.338
	5.079V	18.805W		230.37V

Supplementary Tests (For Reference)

10-110%□□□□

115V

□□	12V	5V	3.3V	5VSB	DC/AC (□)	□□	□□□□ (RPM)	□□□□□□□□ (dB[A])	□□ (□□ /□□)	PF/AC □□
10%	5.180A	1.989A	1.987A	0.978A	84.998	84.819%	0	<6.0	44.58°C	0.968
	12.240V	5.028V	3.322V	5.112V	100.213				40.24°C	115.13V
20%	11.378A	2.986A	2.982A	1.176A	169.957	89.851%	0	<6.0	45.51°C	0.98
	12.220V	5.025V	3.32V	5.101V	189.151				40.69°C	115.11V
30%	17.920A	3.485A	3.48A	1.375A	254.966	91.385%	0	<6.0	46.23°C	0.986
	12.216V	5.022V	3.319V	5.092V	278.997				41.05°C	115.09V
40%	24.466A	3.986A	3.979A	1.574A	340.058	91.404%	0	<6.0	47.18°C	0.989
	12.215V	5.019V	3.318V	5.082V	372.035				41.51°C	115.06V
50%	30.663A	4.986A	4.976A	1.775A	424.958	91.101%	757	20.4	42.24°C	0.989
	12.212V	5.015V	3.316V	5.073V	466.473				48.25°C	115.04V
60%	36.834A	5.987A	5.974A	1.976A	509.496	90.628%	754	20.3	42.56°C	0.989
	12.208V	5.012V	3.315V	5.063V	562.188				49.27°C	115.01V
70%	43.058A	6.99A	6.972A	2.177A	594.836	90.103%	832	23.5	43.27°C	0.989
	12.209V	5.009V	3.314V	5.052V	660.17				50.33°C	114.98V
80%	49.282A	7.994A	7.97A	2.28A	679.672	89.452%	918	26.6	43.58°C	0.99
	12.211V	5.005V	3.312V	5.044V	759.819				51.63°C	114.95V
90%	55.897A	8.497A	8.456A	2.383A	765.098	88.753%	1003	29.1	44.16°C	0.991
	12.212V	5.002V	3.311V	5.036V	862.059				53.21°C	114.93V
100%	62.244A	9.002A	8.973A	2.99A	849.933	87.887%	1196	34.4	45.13°C	0.992
	12.214V	4.999V	3.31V	5.018V	967.074				55.14°C	114.91V
110%	68.457A	10.008A	10.064A	2.994A	934.507	87.015%	1335	38.7	46.84°C	0.993
	12.216V	4.996V	3.308V	5.011V	1073.957				57.78°C	114.88V
CL1	0.114A	11.987A	11.977A	0A	101.291	82.617%	654	6.1	40.31°C	0.973
	12.247V	5.022V	3.314V	5.118V	122.605				45.82°C	115.13V

CL2	0.114A	19.89A	0A	0A	101.391	81.578%	803	22.1	41.94°C	0.973
	12.254V	5.027V	3.313V	5.128V	124.286				48.95°C	115.13V
CL3	0.114A	0A	19.868A	0A	67.397	73.981%	806	22.2	42.87°C	0.96
	12.249V	5.025V	3.322V	5.113V	91.098				52.01°C	115.14V
CL4	69.567A	0A	0A	0A	849.827	88.351%	1264	36.4	45.32°C	0.992
	12.216V	5.007V	3.318V	5.09V	961.882				56.3°C	114.9V

The results above are not used in the certification process

230V

□□	12V	5V	3.3V	5VSB	DC/AC (□)	□□	□□□□ (RPM)	□□□□□□□ (dB[A])	□□ (□□ /□□)	PF/AC □□
10%	5.180A	1.989A	1.987A	0.978A	84.994	85.547%	0	<6.0	44.44°C	0.826
	12.237V	5.028V	3.322V	5.113V	99.354				40.05°C	230.34V
20%	11.380A	2.986A	2.982A	1.176A	169.941	91.242%	0	<6.0	45.23°C	0.916
	12.217V	5.025V	3.32V	5.103V	186.254				40.55°C	230.33V
30%	17.924A	3.485A	3.48A	1.375A	254.948	92.673%	0	<6.0	46.31°C	0.945
	12.212V	5.022V	3.319V	5.093V	275.108				41.03°C	230.33V
40%	24.472A	3.986A	3.978A	1.574A	340.044	93.189%	0	<6.0	47.28°C	0.962
	12.212V	5.019V	3.318V	5.083V	364.896				41.57°C	230.32V
50%	30.666A	4.986A	4.976A	1.774A	424.922	93.063%	757	20.4	42.09°C	0.969
	12.209V	5.015V	3.316V	5.074V	456.593				48.21°C	230.32V
60%	36.834A	5.987A	5.974A	1.975A	509.463	92.879%	754	20.3	42.47°C	0.974
	12.208V	5.012V	3.315V	5.064V	548.526				49.12°C	230.31V
70%	43.058A	6.99A	6.973A	2.177A	594.809	92.609%	832	23.5	43.02°C	0.977
	12.209V	5.009V	3.313V	5.053V	642.279				50.08°C	230.3V
80%	49.283A	7.994A	7.97A	2.28A	679.661	92.222%	919	26.6	43.46°C	0.98
	12.210V	5.005V	3.312V	5.045V	736.981				51.49°C	230.29V
90%	55.899A	8.496A	8.455A	2.383A	765.094	91.836%	1006	29.2	44.04°C	0.982
	12.211V	5.002V	3.311V	5.037V	833.109				53.14°C	230.28V
100%	62.248A	9.002A	8.972A	2.99A	849.936	91.358%	1174	33.8	45.19°C	0.984
	12.213V	4.999V	3.31V	5.018V	930.337				55.27°C	230.27V

110%	68.460A	10.008A	10.065A	2.994A	934.532	90.842%	1336	38.8	47.02°C	0.985
	12.215V	4.996V	3.308V	5.011V	1028.755				57.93°C	230.26V
CL1	0.114A	11.987A	11.977A	0A	101.294	83.796%	653	<6.0	40.56°C	0.861
	12.247V	5.022V	3.314V	5.117V	120.881				46.01°C	230.37V
CL2	0.114A	19.889A	0A	0A	101.392	82.749%	805	22.2	41.76°C	0.863
	12.252V	5.028V	3.313V	5.128V	122.531				49.01°C	230.37V
CL3	0.114A	0A	19.868A	0A	67.397	74.494%	804	22.1	42.85°C	0.806
	12.248V	5.025V	3.322V	5.113V	90.475				51.89°C	230.37V
CL4	69.581A	0A	0A	0A	849.792	91.893%	1218	34.9	45.05°C	0.983
	12.213V	5.007V	3.318V	5.09V	924.769				55.88°C	230.27V

The results above are not used in the certification process

20-80□□□□□

115V

□□	12V	5V	3.3V	5VSB	DC/AC (□)	□□	□□□□ (RPM)	□□□□□□□ (dB[A])	□□ (□□ /□□)	PF/AC □□
20W	1.227A	0.497A	0.496A	0.195A	20	75.256%	0	<6.0	39.65°C	0.833
	12.103V	5.033V	3.325V	5.134V	26.574				36.55°C	115.15V
40W	2.700A	0.696A	0.695A	0.292A	39.997	81.163%	0	<6.0	40.42°C	0.917
	12.108V	5.031V	3.324V	5.13V	49.281				37.07°C	115.15V
60W	4.172A	0.895A	0.894A	0.39A	59.996	83.484%	0	<6.0	41.89°C	0.952
	12.109V	5.031V	3.323V	5.127V	71.865				38.17°C	115.14V
80W	5.582A	1.094A	1.092A	0.488A	79.956	84.766%	0	<6.0	43.13°C	0.962
	12.239V	5.03V	3.323V	5.123V	94.319				39.18°C	115.13V

The results above are not used in the certification process

230V

□□	12V	5V	3.3V	5VSB	DC/AC (□)	□□	□□□□ (RPM)	□□□□□□□ (dB[A])	□□ (□□ /□□)	PF/AC □□
20W	1.226A	0.497A	0.496A	0.195A	19.99	74.648%	0	<6.0	39.59°C	0.486
	12.098V	5.033V	3.324V	5.135V	26.773				36.54°C	230.33V
40W	2.700A	0.696A	0.695A	0.292A	39.99	81.042%	0	<6.0	40.36°C	0.639
	12.104V	5.031V	3.323V	5.132V	49.345				37.05°C	230.33V
60W	4.174A	0.895A	0.893A	0.39A	59.989	84.058%	0	<6.0	41.73°C	0.744
	12.105V	5.031V	3.323V	5.128V	71.363				38.17°C	230.33V
80W	5.584A	1.093A	1.092A	0.488A	79.936	85.324%	0	<6.0	42.88°C	0.818
	12.234V	5.03V	3.323V	5.125V	93.687				39.06°C	230.33V

The results above are not used in the certification process

□□□□

115V

Test	12V	5V	3.3V	5VSB	Pass/Fail
10% Load	8.27mV	5.83mV	8.29mV	13.25mV	Pass
20% Load	23.43mV	5.52mV	7.83mV	10.50mV	Pass
30% Load	16.79mV	4.91mV	7.63mV	10.40mV	Pass
40% Load	13.98mV	5.37mV	7.88mV	11.52mV	Pass
50% Load	13.52mV	8.59mV	8.39mV	23.15mV	Pass
60% Load	13.88mV	8.80mV	9.16mV	23.81mV	Pass
70% Load	14.49mV	9.20mV	9.62mV	24.63mV	Pass
80% Load	14.13mV	9.72mV	13.66mV	25.54mV	Pass
90% Load	14.71mV	10.69mV	14.02mV	25.85mV	Pass
100% Load	23.35mV	12.10mV	16.01mV	27.81mV	Pass
110% Load	23.22mV	12.55mV	16.72mV	28.22mV	Pass
Crossload1	9.38mV	9.81mV	15.18mV	25.13mV	Pass
Crossload2	7.82mV	11.30mV	8.91mV	23.71mV	Pass

Test	12V	5V	3.3V	5VSB	Pass/Fail
Crossload3	10.27mV	10.48mV	17.09mV	23.65mV	Pass
Crossload4	11.78mV	11.94mV	11.78mV	29.07mV	Pass

The results above are not used in the certification process

230V

Test	12V	5V	3.3V	5VSB	Pass/Fail
10% Load	8.22mV	5.78mV	8.39mV	13.97mV	Pass
20% Load	26.39mV	5.52mV	7.62mV	9.99mV	Pass
30% Load	18.63mV	5.27mV	7.42mV	10.71mV	Pass
40% Load	15.31mV	5.42mV	8.08mV	11.52mV	Pass
50% Load	14.80mV	8.95mV	8.39mV	24.16mV	Pass
60% Load	15.20mV	9.16mV	9.01mV	24.47mV	Pass
70% Load	16.33mV	9.36mV	9.52mV	25.70mV	Pass
80% Load	15.82mV	9.97mV	13.25mV	26.41mV	Pass
90% Load	15.26mV	10.07mV	14.02mV	25.85mV	Pass
100% Load	23.82mV	11.85mV	15.39mV	27.09mV	Pass
110% Load	24.77mV	12.62mV	17.26mV	28.09mV	Pass
Crossload1	8.94mV	7.06mV	14.16mV	13.62mV	Pass
Crossload2	7.81mV	11.10mV	8.34mV	23.71mV	Pass
Crossload3	10.06mV	10.64mV	16.94mV	23.91mV	Pass
Crossload4	24.23mV	12.24mV	11.28mV	28.16mV	Pass

The results above are not used in the certification process

Seasonic Vertex GX-850





Top side Power specifications label

本测试报告中包含的所有数据和图表均可在以下条件下由任何人使用：使用过程需提及测试结果由 Cybenetics提供。
在任何情况下都应提供原始测试结果文档的网站链接

Cybenetics 提供自愿性认证计划：电源方面有 ETA（效率）、 LAMBDA（噪声）与 SAFE （安全与正确运行）；散热产品方面有 DELTA（机箱隔音）与 PHI（风扇风量与静压）

CYBENETICS LTD Syrou 6, Latsia, 2231, Nicosia Cyprus www.cybenetics.com - info@cybenetics.com

Cybenetics - Seasonic Vertex GX-850 - Test Report - Page 24 / 24