



Make It Yours.

Cooler Master MWE Bronze 750 V3 230V

☐ MPE7501ACABW3BEU1241500002

Lab ID CM75002526

Certification ID 252526

Test Result Report ID: 24PS2526A

Certificate Issue Date: Aug 7, 2024

115V

230V

Scheme: ETA-EMI PSU



115V

230V



Scheme: LAMBDA PSU



Outside Validation Scope

General Information

Test Equipment

Electronic Loads	Chroma 63601-5 x2 Chroma 63600-2 Chroma 63640-80-80 x10 Chroma 63610-80-20
AC Sources	Chroma 6530, APM SP300VAC4000W-P, GW Instek ASR-3500
Power Analyzers	Rohde & Schwarz HMC8015 & NPA701
Oscilloscopes	Picoscope 4444, Siglent SDS2104X PLUS
Sound Analyzer	Bruel & Kjaer 2270 G4
Microphone	Bruel & Kjaer Type 4955-A
Temperature Logger	Picoscope TC-08
Tachometer	UNI-T UT372
Multimeters	Keysight 34465A
EMI Analyzer	TekBox TBMR-110M-EU
Isolation Transformer	4kVA
UPS	FSP Champ Tower 3kVA, CyberPower OLS3000E 3kVA
Testing Methodology	Cybenetics PSU Test Protocol

DUT Information(Non-accredited measurements)

Product Identification Details	
Brand	Cooler Master
Model	MWE Bronze 750 V3 230V
OEM/ODM	
Serial Number	MPE7501ACABW3BEU1241500002
Product Specifications	
Manufacturer-Provided Information	
$\square\square\square$ (Vrms)	200-240
$\square\square\square$ (Arms)	6

□□□□ (Hz)	50-60
□□□□ (W)	750
Operating Temperature (Continuous Full Load) (°C)	
□□	ATX12V
□□□□	Fixed cables
Warranty	-
Cybenetics Measurements	
Dimensions (W x H x D)	
Weight	
□□	120mm Fluid Dynamic Bearing Fan (HA1225H12F-Z)
□□□□	✓
Cybenetics Testing Information	
Lab ID	CM75002526
Date of receipt	Jul 16, 2024
Testing Date	Aug 7, 2024
Report Issued Date	Aug 7, 2024
□□□□	Broke during 5V SCP testing
Engineer Name	-
Authorized By the Laboratory Technical Manager	Aristeidis Bitziopoulos
Signature	

□□□□ **(Non-accredited measurements)**

□□□□				
□□	□□□□	□□□□□□	Gauge	In Cable Capacitors
ATX □□ 24 pin (510mm)	1	1	18-20AWG	□
8 pin EPS 12V □□ (560mm) / 4+4 pin EPS 12V □□ (+120mm)	1	2	18AWG	□
6+2pin PCIe□□ (540mm+100mm)	2	4	16-18AWG	□
SATA□□ (420mm+150mm+150mm)	2	6	18-20AWG	□
4-pin Molex (400mm+150mm+150mm)	1	3	18-20AWG	□
□□□□				

AC Power Cord (1385mm) - C13 coupler	1	1	18AWG	-
--------------------------------------	---	---	-------	---

Protection Features(Manufacturer)

Over Power Protection	✓
Over Current (+12V) Protection	✓
Over Temperature Protection	✓
Short Circuit Protection	✗
Surge Protection	✓
Inrush Current Protection	✓
Fan Failure Protection	✗

		3.3V	5V	12V	5VSB	-12V
		20	20	62	3	0.3
		120		744	15	3.6
	(W)	750				

Test Results

Temperature & Compliance Info

(°C /°F)	28-32 / 82.4-89.6
ErP Lot3/6	✓
(EU) No 617/2013	✓
ALPM (Alternative Low Power Mode) compatible	✓
ATX v3.1 PSU Power Excursion	✓

Performance Summary 230V

Accredited	
(>1450 load combinations)	87.812%
Average Noise Output (>1450 Load Combinations)	38.77dBA

PF _{min} (>1450 Load Combinations)	0.958	
Efficiency With 10W (≤500W) or 2% (>500W) Load	-	
THD _{min}	0.1801W	
Non-Accredited		
12V Ripple (Full Load)	40.28mV	
5V Ripple (Full Load)	22.91mV	
3.3V Ripple (Full Load)	18.16mV	
5VSB Ripple (Full Load)	52.06mV	
12V Load Regulation	1.98%	
5V Load Regulation	3.19%	
3.3V Load Regulation	4.93%	
5VSB Load Regulation	4.57%	
Inrush Current	126.700A	
12V Transient Response (150%)	11.61V	
5V Transient Response (150%)	4.945V	
3.3V Transient Response (150%)	3.168V	
5VSB Transient Response (150%)	4.958V	
THD _{max} & PG _{min}	21.00ms	
AC Loss to PWR_OK Hold Up Time	19.60ms	
PWR_OK Inactive to DC Loss Delay	1.40ms	
PSU Timings: T1 (20% / 100%)	58.0ms	58.0ms
PSU Timings: T3 (20% / 100%)	125.0ms	126.0ms
OPP (30.15°C / 0.00°C)	132.18%	-

THD_{max} & PG_{min}

Hold-Up Time (ms)	21
AC Loss to PWR_OK Hold Up Time (ms)	19.6
PWR_OK Inactive to DC Loss Delay (ms)	1.4




Tables 230V

Detailed Results						
	Average	Min	Limit Min	Max	Limit Max	Result
Mains Voltage RMS:	231.06 V	230.96 V	227.70 V	231.12 V	232.30 V	PASS
Mains Frequency:	50.00 Hz	49.99 Hz	49.50 Hz	50.01 Hz	50.50 Hz	PASS
Mains Voltage CF:	1.417	1.417	1.340	1.419	1.490	PASS
Mains Voltage THD:	0.17 %	0.15 %	N/A	0.26 %	2.00 %	PASS
Real Power:	0.180 W	0.147 W	N/A	0.219 W	N/A	N/A
Apparent Power:	51.182 W	50.902 W	N/A	51.507 W	N/A	N/A
Power Factor:	0.003	N/A	N/A	N/A	N/A	N/A




230V



This graph depicts the PSU's efficiency throughout its entire operational range. For the generation of the efficiency and noise graphs we set our loaders to auto mode through our custom-made software before trying thousands of possible load combinations



230V




The PSU's noise in its entire operational range and under 30-32 °C ambient is depicted in this graph. The X axis represents the load on the +12V rail(s) while the Y axis is the load on the minor rails

Indicative Performance



Efficiency: Cooler Master MWE BRONZE 750 V3 230V

Ambient: 36°C - 46°C (96.8°F - 114.8°F)




The PSU`s efficiency under high ambient temperatures with 115V and 230V input. For this graph the results of the 10-110% load regulation table are used

5Vsb

5VSB Efficiency: Cooler Master MWE BRONZE 750 V3 230V

Ambient: 34°C - 36°C (93.2°F - 96.8°F)



This graph depicts the efficiency levels of the 5VSB rail with 115V and 230V input

5Vsb (ErP Lot3/6 & CEC) 230V

#	5VSB	DC/AC ()		PF/AC
1	0.045A	0.231W	47.665%	0.01
	5.137V	0.485W		230.37V

2	0.09A	0.462W	60.045%	0.016
	5.136V	0.77W		230.37V
3	0.55A	2.818W	76.218%	0.074
	5.122V	3.698W		230.37V
4	1A	5.11W	77.627%	0.126
	5.108V	6.585W		230.36V
5	1.5A	7.641W	78.059%	0.177
	5.093V	9.79W		230.36V
6	3.001A	15.142W	77.091%	0.289
	5.047V	19.641W		230.36V

Protection Features

OCP (Cold @ -°C)	-
OCP (Hot) @ -°C	-
OPP (Cold @ 30.1°C)	991.35W (132.18%)
OPP (Hot @ -°C)	-
OTP	
SCP	12V to Earth: ✓ 5V to Earth: ✗ 3.3V to Earth: - 5VSB to Earth: ✓ -12V to Earth: -
PWR_OK	Proper Operation
NLO	✓
Fan Failure Protection	✗
SIP	Surge: MOV Inrush: NTC & Bypass Relay

Supplementary Tests (For Reference)

10-110%
230V

	12V	5V	3.3V	5VSB	DC/AC ()		(RPM)	(dB[A])	(/)	PF/AC
10%	4.367A	1.95A	1.973A	0.982A	75.006	83.099%	1525	34.1	40.21°C	0.801
	12.229V	5.129V	3.346V	5.09V	90.261				41.97°C	230.4V
20%	9.764A	2.935A	2.973A	1.184A	149.976	88.636%	1647	36	40.66°C	0.92
	12.194V	5.112V	3.33V	5.071V	169.203				42.4°C	230.4V
30%	15.526A	3.433A	3.483A	1.386A	224.995	89.778%	1895	40.9	41.3°C	0.956
	12.169V	5.099V	3.317V	5.053V	250.618				43.18°C	230.4V
40%	21.312A	3.934A	3.997A	1.59A	300.1	89.989%	2120	42.8	41.88°C	0.971
	12.147V	5.086V	3.303V	5.034V	333.486				43.86°C	230.4V
50%	26.743A	4.934A	5.022A	1.796A	374.799	89.667%	2343	45.3	42.14°C	0.979
	12.126V	5.069V	3.286V	5.013V	417.991				44.32°C	230.39V
60%	32.207A	5.94A	6.056A	2.001A	449.663	89.15%	2347	45.4	42.68°C	0.984
	12.105V	5.053V	3.27V	4.993V	504.389				44.98°C	230.38V
70%	37.691A	6.953A	7.102A	2.213A	524.567	88.538%	2349	45.4	43.18°C	0.987
	12.083V	5.036V	3.253V	4.972V	592.477				46.26°C	230.36V
80%	43.264A	7.972A	8.158A	2.322A	599.767	87.744%	2353	45.5	43.63°C	0.988
	12.062V	5.018V	3.236V	4.954V	683.542				47.23°C	230.35V
90%	49.189A	8.495A	8.692A	2.432A	674.779	86.866%	2354	45.5	44.51°C	0.99
	12.041V	5.004V	3.221V	4.936V	776.801				48.5°C	230.33V
100%	54.935A	9.023A	9.265A	3.062A	750	85.743%	2357	45.5	45.07°C	0.991
	12.020V	4.988V	3.205V	4.9V	874.704				50.22°C	230.32V
110%	60.577A	10.063A	10.449A	3.073A	825.031	84.354%	2363	45.6	46.31°C	0.992
	11.997V	4.969V	3.186V	4.882V	978.066				52.52°C	230.31V
CL1	0.115A	14.337A	14.579A	0.001A	121.309	80.304%	2288	44.8	40.65°C	0.906
	12.208V	5.036V	3.272V	5.083V	151.064				44.01°C	230.4V
CL2	0.114A	19.88A	0A	0.001A	101.404	79.349%	2094	42.6	40.05°C	0.878
	12.222V	5.03V	3.335V	5.104V	127.798				42.49°C	230.4V

CL3	0.114A	0A	20.186A	0.001A	67.401	72.108%	2024	41.9	40.99°C	0.811
	12.215V	5.116V	3.269V	5.098V	93.473				43.06°C	230.41V
CL4	62.374A	0A	0A	0.001A	749.853	86.929%	2363	45.6	45.47°C	0.991
	12.021V	5.058V	3.262V	5.018V	862.621				49.35°C	230.33V

The results above are not used in the certification process

20-80 230V

	12V	5V	3.3V	5VSB	DC/AC ()		(RPM)	(dB[A])	(/)	PF/AC
20W	1.216A	0.486A	0.491A	0.195A	20.012	78.99%	0	<6.0	41.64°C	0.382
	12.226V	5.147V	3.363V	5.124V	25.336				36.12°C	230.42V
40W	2.668A	0.681A	0.688A	0.293A	40.007	84.823%	0	<6.0	42.74°C	0.59
	12.258V	5.143V	3.359V	5.118V	47.169				37.11°C	230.41V
60W	4.130A	0.876A	0.885A	0.391A	60.003	80.734%	1437	32.4	38.87°C	0.746
	12.234V	5.139V	3.355V	5.112V	74.324				40.1°C	230.41V
80W	5.588A	1.072A	1.083A	0.49A	79.97	84.547%	1402	31.4	39.28°C	0.813
	12.228V	5.135V	3.351V	5.106V	94.587				40.76°C	230.4V

The results above are not used in the certification process

230V

Test	12V	5V	3.3V	5VSB	Pass/Fail
10% Load	7.68mV	13.98mV	8.24mV	34.95mV	Pass
20% Load	23.64mV	13.42mV	8.24mV	33.98mV	Pass
30% Load	22.32mV	13.62mV	8.69mV	34.34mV	Pass
40% Load	22.17mV	14.18mV	9.00mV	34.59mV	Pass
50% Load	23.14mV	15.15mV	10.32mV	37.39mV	Pass
60% Load	22.93mV	16.53mV	12.67mV	39.48mV	Pass
70% Load	23.24mV	17.19mV	11.70mV	40.50mV	Pass
80% Load	24.46mV	18.26mV	15.62mV	41.06mV	Pass
90% Load	24.97mV	19.33mV	15.67mV	43.20mV	Pass
100% Load	40.28mV	22.91mV	18.16mV	52.06mV	Fail


Test	12V	5V	3.3V	5VSB	Pass/Fail
110% Load	44.26mV	24.02mV	19.52mV	53.96mV	Fail
Crossload1	38.77mV	26.95mV	23.67mV	40.61mV	Pass
Crossload2	13.49mV	37.54mV	13.02mV	36.58mV	Pass
Crossload3	11.25mV	14.54mV	24.77mV	33.73mV	Pass
Crossload4	39.40mV	16.13mV	9.24mV	43.06mV	Pass

The results above are not used in the certification process

Cooler Master MWE Bronze 750 V3 230V



Top side



Power specifications label

XXXXXXXXXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXXXXXXXXX

Cybenetics[] []

Cybenetics [] [] [] [] [] [] [] []
XXXXXXXXXXXXXXXXXXXX

ETA[] [] [] []
DELTA[] [] [] [] [] []

LAMBDA[] [] [] []
PHI[] [] [] [] [] []

SAFE

CYBENETICS LTD Syrou 6, Latsia, 2231, Nicosia Cyprus

www.cybenetics.com - info@cybenetics.com